



中国船级社
CHINA CLASSIFICATION SOCIETY

证书编号/Certificate No.
BG19PTB00026

型式认可证书
CERTIFICATE OF TYPE APPROVAL

兹证明本证书所述制造厂具备按照下列标准的要求生产本证书所列产品的能力和条件。

This is to certify that the manufacturer stated in the certificate meets the requirements of the standards listed below and is available with the ability and conditions to produce the products described in the certificate.

制造厂/Manufacturer

Autronica Fire and Security AS

地址/Address

Bromstadveien 59, Trondheim, Norway

产品名称/Product

固定式探火和失火报警系统部件
Components for Fixed Fire Detection and Alarm System
火灾探测器, 手动报警按钮
Fire Detector, Alarm Manual Points

附加标志/Notations

无/Nil.

认可标准/Approval Standard

1. 经MSC. 311(88)修正的《国际消防安全系统规则》第9章
Chapter 9 of International Code For Safety Systems, as amended by MSC311(88)
2. 1974年国际海上人命安全公约及其修正案第II-2章第7条
Regulations 7, Chapter II -2 of International Convention For The Safety Of Life At Sea, 1974, as Amended

用于/Intended for

船舶与海上设施/Ships and Offshore Installations

证书有效期至/This Certificate is valid until 2023年12月19日/ Dec. 19, 2023

发证机构 中国船级社卑尔根办事处
Issued by CCS Bergen Office

签发日期 2019年12月20日
Date Dec. 20, 2019

本证书根据中国船级社规范和相关规定签发。所有证书页为一个整体，必须同时使用。纸质证书每页均须由本社盖章方为有效，电子证书含数字签名方为有效。本证书复印件无效。任何单位和个人均不应摘录或节选本证书的部分内容。有关方对所持证书的真实性有疑问时，可以向本社检验机构咨询。
This Certificate is issued pursuant to the Rules of the Society and related regulation. All pages of the certificate are taken as a whole and are used simultaneously. No paper certificate page is valid without bearing the stamp of the Society, no electronic certificates is valid without the digital signature, and no copied form of the certificate is regarded as valid. Any part of the certificate is not to be extracted or abridged by any unit or individual in any form. Related parties who are doubted about the authenticity of the certificate may inquire of the Society or its offices.



Form No: T01.

联系方式/Contact Us. 见本社官方网站/See official web site of the Society (<http://www.ccs.org.cn>)

UTN:P019-99889746



产品明细/Product Description

火灾探测器/Fire Detector (M001)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Optical smoke detector without self-verify	
型号/Type	BH-200	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M002)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Optical smoke detector with self-verify	
型号/Type	BH-300	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M003)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Optical smoke detector with self-verify, environmentally protected	
型号/Type	BH-500	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M004)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Optical smoke detector with self-verify	
型号/Type	BH-500/Ex	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ia	

火灾探测器/Fire Detector (M005)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Optical smoke detector with self-verify	
型号/Type	BH-500/N	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ic	

火灾探测器/Fire Detector (M006)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Multi-sensor detector without self-verify, smoke / heat	
型号/Type	BH-220	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M007)

名称/Name	属性(值)/Value	单位/Unit
名称/Name	属性(值)/Value	单位/Unit

产品名称/Product Name	Multi-sensor detector with self-verify, smoke / heat	
型号/Type	BH-320	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M008)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Multi-sensor detector with self-verify, environmentally protected, smoke / heat	
型号/Type	BH-520	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M009)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Multi-sensor detector with self-verify, smoke / heat	
型号/Type	BH-520/Ex	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ia	

火灾探测器/Fire Detector (M010)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Multi-sensor detector with self-verify, smoke / heat	
型号/Type	BH-520/N	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ic	

火灾探测器/Fire Detector (M011)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector without self-verify	
型号/Type	BD-200	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M012)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-300	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M013)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify, environmentally protected	
型号/Type	BD-500	

外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M014)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-500/Ex	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ia	

火灾探测器/Fire Detector (M015)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-500/N	
外壳防护等级/Degree of Protection of Enclosure	IP44D	
防爆标志/Explosion-Proof Marking	Ex ic	

火灾探测器/Fire Detector (M016)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-501	
外壳防护等级/Degree of Protection of Enclosure	IP56	
防爆标志/Explosion-Proof Marking	N. A.	

火灾探测器/Fire Detector (M017)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-501/Ex	
外壳防护等级/Degree of Protection of Enclosure	IP56	
防爆标志/Explosion-Proof Marking	Ex ia	

火灾探测器/Fire Detector (M018)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector with self-verify	
型号/Type	BD-501/N	
外壳防护等级/Degree of Protection of Enclosure	IP56	
防爆标志/Explosion-Proof Marking	Ex ic	

火灾探测器/Fire Detector (M019)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Heat detector without self-verify	
型号/Type	BD-200M	
外壳防护等级/Degree of Protection of Enclosure	IP56	
防爆标志/Explosion-Proof Marking	N. A.	

手动报警按钮/Alarm Manual Points (M001)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-300 Manual call point with self-verify	

外壳防护等级/Degree of Protection of Enclosure	IP24	
防爆标志/Explosion-Proof Marking	N. A.	

手动报警按钮/Alarm Manual Points (M002)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-300M Manual call point with self-verify, metal housing w/PG16 glands	
外壳防护等级/Degree of Protection of Enclosure	IP44	
防爆标志/Explosion-Proof Marking	N. A.	

手动报警按钮/Alarm Manual Points (M003)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-300M/N Manual call point with self-verify, PG16 glands	
外壳防护等级/Degree of Protection of Enclosure	IP44	
防爆标志/Explosion-Proof Marking	Ex ic	

手动报警按钮/Alarm Manual Points (M004)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-502 Manual call point with self-verify, M20 glands	
外壳防护等级/Degree of Protection of Enclosure	IP66/67	
防爆标志/Explosion-Proof Marking	N. A.	

手动报警按钮/Alarm Manual Points (M005)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-502/Ex Manual call point with self-verify, M20 glands	
外壳防护等级/Degree of Protection of Enclosure	IP66/67	
防爆标志/Explosion-Proof Marking	Ex ia	

手动报警按钮/Alarm Manual Points (M006)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-502/N Manual call point with self-verify, M20 glands	
外壳防护等级/Degree of Protection of Enclosure	IP66/67	
防爆标志/Explosion-Proof Marking	Ex ic	

手动报警按钮/Alarm Manual Points (M007)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-300V2 Manual call point with self-verify	
外壳防护等级/Degree of Protection of Enclosure	IP42D / IP44D	
防爆标志/Explosion-Proof Marking	N. A.	

手动报警按钮/Alarm Manual Points (M008)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-500V2/Ex Manual call point with self-verify	
外壳防护等级/Degree of Protection of Enclosure	IP42D / IP44D	

防爆标志/Explosion-Proof Marking	Ex ia	
------------------------------	-------	--

手动报警按钮/Alarm Manual Points (M009)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	BF-510WP-H Manual call point with self-verify, weatherproof	
外壳防护等级/Degree of Protection of Enclosure	IP52 / IP55	
防爆标志/Explosion-Proof Marking	N. A.	

批准的图纸/Approved Drawings

图纸批准号/Drawings Approval No.: BG19PPP20018

产品认可试验报告/Approval Test Report

试验报告编号/Test Report No.: 98-1390, Rev. 1

试验报告日期/Test Report Date: 1998-11-19

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: TE89823

试验报告日期/Test Report Date: 1999-02-12

试验单位/Laboratory: LPC

试验单位地址/Test Address: BRITAIN

试验报告编号/Test Report No.: BFS/DE/1057-1999. 12. 09

试验报告日期/Test Report Date: 1999-12-09

试验单位/Laboratory: ANPI

试验单位地址/Test Address: BELGIUM

试验报告编号/Test Report No.: 99-1491, Rev. 2

试验报告日期/Test Report Date: 2000-01-04

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: 2000-1178, Rev. 2

试验报告日期/Test Report Date: 2000-03-13

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: TE200205

试验报告日期/Test Report Date: 2001-01-11

试验单位/Laboratory: LPC

试验单位地址/Test Address: BRITAIN

试验报告编号/Test Report No.: 2001-3252, Rev. 1

试验报告日期/Test Report Date: 2001-07-12

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: 2001-3416, Rev. 1

试验报告日期/Test Report Date: 2001-10-11

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: 2002-3146, Rev. 03

试验报告日期/Test Report Date: 2002-02-26

试验单位/Laboratory: DNV

试验单位地址/Test Address: NORWAY

试验报告编号/Test Report No.: BFS/REDI/154-2005. 06. 03

试验报告日期/Test Report Date: 2005-06-03

试验单位/Laboratory: ANPI

试验单位地址/Test Address: BELGIUM

试验报告编号/ Test Report No. : BFS/REDT/155-2005.06.16
试验报告日期/ Test Report Date : 2005-06-16
试验单位/ Laboratory: ANPI
试验单位地址/ Test Address: BELGIUM

试验报告编号/ Test Report No. : TF221656
试验报告日期/ Test Report Date : 2005-08-18
试验单位/ Laboratory: BRE
试验单位地址/ Test Address: BRITAIN

试验报告编号/ Test Report No. : 1975/BA/04
试验报告日期/ Test Report Date : 2006-06-06
试验单位/ Laboratory: CNBOP
试验单位地址/ Test Address: POLAND

试验报告编号/ Test Report No. : BA0678/400/2720/07
试验报告日期/ Test Report Date : 2007-08-02
试验单位/ Laboratory: CNBOP
试验单位地址/ Test Address: POLAND

试验报告编号/ Test Report No. : DE080071
试验报告日期/ Test Report Date : 2008-12-23
试验单位/ Laboratory: CNPP
试验单位地址/ Test Address: FRANCE

试验报告编号/ Test Report No. : DE080073
试验报告日期/ Test Report Date : 2008-12-23
试验单位/ Laboratory: CNPP
试验单位地址/ Test Address: FRANCE

试验报告编号/ Test Report No. : DE080070
试验报告日期/ Test Report Date : 2008-12-23
试验单位/ Laboratory: CNPP
试验单位地址/ Test Address: FRANCE

试验报告编号/ Test Report No. : 2009-3598, Rev. 2
试验报告日期/ Test Report Date : 2009-11-20
试验单位/ Laboratory: DNV
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : 2010-3107, Rev. 1
试验报告日期/ Test Report Date : 2010-05-05
试验单位/ Laboratory: DNV
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : 180163
试验报告日期/ Test Report Date : 2011-11-08
试验单位/ Laboratory: NEMKO
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : 187270
试验报告日期/ Test Report Date : 2011-12-15
试验单位/ Laboratory: NEMKO
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : 187271
试验报告日期/ Test Report Date : 2011-12-15
试验单位/ Laboratory: NEMKO
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : E12044.00
试验报告日期/ Test Report Date : 2012-05-29
试验单位/ Laboratory: NEMKO
试验单位地址/ Test Address: NORWAY

试验报告编号/ Test Report No. : E18217.00
试验报告日期/ Test Report Date : 2018-11-15
试验单位/ Laboratory: Nemko

试验单位地址/ Test Address: Gaustadalleen 30, 0314 Oslo, Norway

试验报告编号/ Test Report No.: 187264-01
 试验报告日期/ Test Report Date: 2016-04-08
 试验单位/ Laboratory: Nemko
 试验单位地址/ Test Address: Gaustadalleen 30, 0314 Oslo, Norway

试验报告编号/ Test Report No.: E12028.01
 试验报告日期/ Test Report Date: 2017-02-20
 试验单位/ Laboratory: Nemko
 试验单位地址/ Test Address: Gaustadalleen 30, 0314 Oslo, Norway

试验报告编号/ Test Report No.: E12031.00
 试验报告日期/ Test Report Date: 2011-12-15
 试验单位/ Laboratory: Nemko
 试验单位地址/ Test Address: Gaustadalleen 30, 0314 Oslo, Norway

认可后的产品检验方式/ Method of Product Inspection after Approval

按规范认可后应进行产品检验的产品/The product should be inspected in term of the rules;
 认可后的产品检验应由本社验船师根据本社规范规定按批准的产品检验计划进行检验, 经检验合格后由本社颁发船用产品证书。

After approval, product inspection should be carried out by the Surveyor of the Society in accordance with the approved product inspection scheme, and the Marine Product Certificate will be issued by the Society upon satisfactory inspection.

认可保持条件/ Maintenance Requirements of Approval

1. 型式认可后, 如果产品及其重要零部件的设计、所用材料或制造方法有所改变, 且影响到产品的主要特性、特征; 或产品的性能指标有所更改, 且超过认可的范围, 则有关图纸和文件应经检验机构审批。并在检验机构认为必要时, 给本社检验人员见证有关试验和进行检查, 其结果应能证实仍符合认可条件。

After type approval, if there are changes to the design, materials used or manufacturing method of the product and important components and such changes affect major characteristics and properties of the product, or property indexes of the product are changed and exceed the scope of approval, related drawings and documents are to be examined and approved by the concerned survey office. Where deemed necessary by the survey office, the surveyor to the Society will go to witness relevant tests and conduct inspection and the results should be able to demonstrate compliance with the approval conditions.

2. 工厂的质量管理体系应保持有效运行, 并且与认可时一致。如果质量管理体系发生改变, 应经原体系认证机构审核并报本社批准。

The quality management system of the factory shall be ensure effective operation, and shall be the same as the situation of approval. If there are any changes to the quality management system, auditing of the original certification organization for quality management system and the society's approval shall be obtained.

3. 认可证书有效期内, 如果出现可能导致本社取消认可的情况, 工厂应及时采取有效的纠正措施。

Within the validity of the approval certificate, if cases occur that may cause the Society to withdraw the approval, the manufacturer should take corrective actions in a prompt and effective manner.

4. 在认可证书有效期内, 本社检验人员可在未经事先通知的情况下对工厂的产品制造过程进行审核, 以验证产品的生产是否符合业经本社批准的图纸和文件。工厂应予以配合。

Within the validity of the approval certificate, the surveyor to the Society may pay unannounced audit to the manufacturing process of the product in order to confirm whether it is in compliance with the drawings and documents approved by the Society. The factory should provide an active cooperation and necessary for the surveyor.

5. 如果属于获得型式认可B模式证书, 且无需颁发船用产品证书/等效证明文件的情况, 证书获得者应接受本社每年一次的定期审核, 定期审核日为认可证书期满之日对应的每一周年日, 检查工作应在周年日的前后三个月内进行。

If belong to the situation of the product has type approval mode B certificate, and marine product certificate/equivalent document is not necessary, those who have obtained the certificate should be subject to periodical audit every year. The date of periodical audit shall be each anniversary date which corresponds to the date of expiry of the relevant certificate and the periodical audit shall be done within a time span of three months before and after the annual surveillance date.

备注/Remarks

1. 本证书由原型式认可证书 (No. BG15T00019) 换新并替代原证书。

This certificate is renewed from and supersedes the previous Type Approval Certificate No. BG15T00019.

II. For some more details of other optional components such as address interface units, additional field equipment, conduit and sockets please refer to the additional page.

III. The Ex-Proof parameters of the approved products originate from Ex-Certificate provided from manufacturer. This type approval certification will be invalid if the approved products don't hold valid Ex-Certificate.

IV. 本社已审核了产品厂无石棉声明，但本社的审核不免除产品厂按照合同关系向订货方保证产品无石棉的责任。
The declaration of asbestos-free submitted by manufacturer has been reviewed by the Society.
However, liability of the manufacturer to guarantee the products are asbestos-free to purchaser under contract will not be exempted.

中国船级社卑尔根办事处

CCS Bergen Office 09

注：本证书含有附页，共1页

Note: The certificate is attached with additional 1 page(s)