



MANUFACTURER DECLARATION OF CONFORMITY

FOR

Product identification:

Model/type: Refer to model listing
 Category (description): Fire detection and fire alarm systems
 Brand: Autronica


Initial year affixing UKCA mark: 2022

Manufacturer: Autronica Fire & Security AS
 Bromstadvegen 59,
 NO-7483 Trondheim
 Norway

Authorized representative: --

Concerning	A sample of the product has been tested by	Test report reference	Applied standards
EMC	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_rev2	EN 61000-6-3:2007+A1:2011+AC:2012 EN 50130-4:2011
CPR	DBI Certification-UK Ltd. Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH	Certificate: 8504-UKCA-CPR-UKCSP10118	EN 54-17:2005+AC:2007
ATEX	DNV Product Assurance AS Veritasveien 1 1363 Høvik Norway	Certificate: DNV 21ATEX14779X DNV 22ATEX13772X	EN IEC 60079-0:2018 EN 60079-11:2012
RoHS	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway	CQP_AutroGuard_rev2	EN IEC 63000:2018

Restrictions on putting into service / requirements for authorization of use

Not applicable None 

Means of conformity

We declare under our sole responsibility that this product is in conformity with Regulations: S.I. 2019/696 (Marking), S.I. 2016/1091 (EMC), 305/2011 + S.I. 2020/1359 (CPR), S.I. 2016/1107 (ATEX) and S.I. 2012/3032 (RoHS) and complies with the essential requirements and all other relevant provisions of the Regulations based on test results using designated standards in accordance with the Regulations mentioned.

In accordance with the "UK Conformity Assessment - GOV.UK" guidelines, UKCA marking in relation to the provisions of the S.I. 2016/1107 (ATEX) was placed based on the EU CAB certification and relevant Designated Standards.

ATEX:



II 1 G Ex ia IIC T5 Ga Tamb -30°C ≤ Ta ≤ +70°C



II 3 G Ex ic IIC T5 Gc Tamb -30°C ≤ Ta ≤ +70°C

Signed on behalf of manufacturer:

Signed by:

Aleksandra Strzelec-Sierpińska

Aleksandra Strzelec-Sierpińska, Compliance Team Manager
 Autronica Fire & Security AS
 Bromstadvegen 59,
 NO-7483 Trondheim, Norway

Place: Gdańsk, Poland

Date: 17 February 2026

Model listing (List of all product variants or models for which this declaration is valid)

Model	Description
V-100 series	AutroGuard base for multicriteria protector V-430 series
V-110	AutroGuard base with SIL2 certification, with remote LED output for multicriteria protector V-530 series
V-120 series	AutroGuard Ex base with SIL2 certification for multicriteria protector V-530 series

Full model codes of the series are as follow:
V-100-yy/ww where:
-yy - Color (Blank = White, BK = Black, CC = Custom color);
/www - version (Blank = Standard, M = Maritime certified, AP = Autroprime compatible, APM = Autroprime maritime certified);
V-120/ww where:
/ww - version (Blank = Standard, AP = Autroprime compatible);

Signed on behalf of manufacturer:

Signed by:



Place: Gdańsk, Poland

Date: 17 February 2026

Aleksandra Strzelec-Sierpińska, Compliance Team Manager
Autronica Fire & Security AS
Bromstadvegen 59,
NO-7483 Trondheim, Norway