



DECLARATION OF PERFORMANCE

No. 60.1010926 rev2

According to the Construction Products Regulation
305/2011 + S.I. 2020/1359

Unique identification code of the product type:	Brand(s): Autronica Model(s): <i>see Model listing</i>
Type, batch, or serial number:	<i>Each individual product is identified with a label containing a unique serial number</i>
Intended use:	Fire detection and fire alarm systems
Name, registered trade name, or registered trademark and contact address of the manufacturer:	Autronica Fire & Security AS Bromstadvegen 59, NO-7483 Trondheim Norway
Name and contact address of the authorized representative:	--
System or systems of AVCP:	System 1
Declaration of performance concerning a construction product is covered by a designated standards: EN 54-10:2002+A1:2005	BRE Global Limited (UK) - 0832 , performed type testing, the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued a certificate of constancy of performance: 0832-UKCA-CPR-F1506 .

Declared performance:

Essential characteristics	Performance	Harmonised technical specification:
Operational reliability	Pass	EN 54-10:2002+A1:2005 Clause: 5.2 to 5.6
Durability of operational reliability; Temperature resistance	Pass	EN 54-10:2002+A1:2005 Clause: 5.7, 5.8
Durability of operational reliability; vibration resistance	Pass	EN 54-10:2002+A1:2005 Clause: 5.12 to 5.15
Durability of operational reliability; humidity resistance	Pass	EN 54-10:2002+A1:2005 Clause: 5.9, 5.10
Durability of operational reliability; corrosion resistance	Pass	EN 54-10:2002+A1:2005 Clause: 5.11
Durability of operational reliability; electrical stability	Pass	EN 54-10:2002+A1:2005 Clause: 5.16, 5.17

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation 305/2011 + S.I. 2020/1359, under the sole responsibility of the manufacturer identified above.

Model listing (List of all product variants or models for which this declaration is valid):

Model	Description
X33AF series	AutroFlame Multispectrum IR Flame Detector

Signature of representative/manufacturer:

Aleksandra Strzelec-Sierpińska

0EC137DC6D54E6...

Place: Gdańsk, PL

Date: 25 June 2025

Aleksandra Strzelec-Sierpińska, Compliance Manager

Autronica Fire & Security AS
Bromstadvegen 59,
NO-7483 Trondheim, Norway