

## EC CERTIFICATE OF CONFORMITY

0883 - CPD - 0019

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Interactive Fire Detection System

Product	Brand	Туре
Main Panel	Autroprime	BS-200
Main Panel (agricultural)	Autroprime	BS-200L
Operator Panel	Autroprime	BS-210
Repeater Panel	Autroprime	BS-211
Information Panel	Autroprime	BV-210
Fire Brigade Panel	Autroprime	BU-210
Alarm Storing Panel	Autroprime	BU-211
LED Mimic Driver	Autroprime	BUR-200

placed on the market by and produced in the factory of:

## AUTRONICA Fire and Security AS Haakon VII's gate 4 N-7483 Trondheim, Norway

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body – Nemko Certification AS - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 54-2:1997 / A1:2006 EN 54-4:1997 / A1:2002 / A2:2006

were applied and that the product fulfils all the prescribed requirements. This certificate was first issued on 27. February 2008 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Oslo, 27.02.2008

Kirsten Svindahl

