Certificate No.: 8504-UKCA-CPR-UKCSP10228



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

BBQ-230 and BBQ-230/IP Sounder VAD with Short Circuit Isolator

The product fulfils the	essential characteristic:	
	See Annex 1	
Intended use:	Applications related to aut	omatic fire alarm systems
Placed on the market u	under the name or trade mark of:	
	Autronica Fire and Security	/ AS
	Bromstadvegen 59	
	NO-7047 Trondheim	
	Norway	
and produced in the m	nanufacturing plant:	
	CPA10061	
This attests that all pro	ovisions concerning the performance describ	ed in Annex ZA of the standard(s)
EN 54-3:2001+A1:2002	2+A2:2006 : Fire detection and fire alar	m systems — Part 3: Fire alarm devices — Sounders

EN 54-3:2001+A1:2002+A2:2006	:	Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders
EN 54-17:2005+AC:2007	:	Fire detection and fire alarm systems — Part 17: Short circuit isolators
EN 54-23:2010	:	Fire detection and fire alarm systems — Part 23: Fire alarm devices — Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2023-02-16 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2023-02-16.

21

Merete Poulsen Responsible for evaluation

Chris Ellis Responsible for certification decision



Certificate No.: 8504-UKCA-CPR-UKCSP10228



Annex 1

EXTENT

Type:	

BBQ-230 and BBQ-230/IP Sounder VAD with Short Circuit Isolator

Compliant Settings:

Model number: BBQ-230

Parameter:	Value:	
Voltage Max	25V	
Voltage Min	17V	
Sound Type	Tone A General Alarm	
VAD On/Off	On (Flashing at 1Hz)	
IP rating	IP21C	

Model number: BBQ-230/IP					
Parameter:	Value:				
Voltage Max	25V				
Voltage Min	17V				
Sound Type	Tone A General Alarm				
VAD On/Off	On (Flashing at 1Hz)				
IP rating	IP33C				

Conditions of use:

Model number BBQ-230: Suitable for indoor applications only (degree of protection Type A/IP21C) Model number BBQ-230/IP: Suitable for outdoor applications (degree of protection Type B/IP33C)

Performance

Essential characteristics	Clauses in EN 54-3:2001/A1:2002/A	2:2006 Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4	Pass
Durability of operational reliability and response delay; temperature resistance	5.5, 5.6, 5.7, 5.8, 5.9	Pass
Durability of operational reliability; humidity resistance	5.8, 5.9, 5.10	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; electrical stability	5.16	Pass
Durability of operational reliability; resistance to ingress	5.17	Pass
5.6 and 5.10 applies only to outdoor sound 5.16 applies only to sounders or voice soun		ese clauses only apply for model BBQ-230/IP







Essential characteristics	Clauses in EN 54-17:2005	Performance		
Performance under fire conditions	5.2 ¹⁾	Pass		
Operational reliability	4 ²⁾	Pass		
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass		
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass		
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass		
Durability of operational reliability; corrosion resistance	5.8	Pass		
Durability of operational reliability; electrical stability	5.3, 5.13	Pass		

This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices
There is no provision for connection of ancillary devices and this device does not incorporate a LED indicator. Therefore the clauses
4.2 and 4.3 are not applicable.

Essential charac	teristics		Clauses in EN 54-23:20	Level(s) or	Notes
			LIN 34-23.20	 class(es)	
Operational reliability:					
Duration of operation			4.2.1		Pass
Provision for external conduct	ors		4.2.2		Pass
Flammability of materials			4.2.3		Pass
Enclosure protection			4.2.4		Pass
Access			4.2.5		Pass
Manufacturer's adjustments			4.2.6		Pass
On-site adjustment of behavio	ur		4.2.7		Pass
Requirements for software co			4.2.8		Pass
Performance parameters under fi	re condition:	1			
Coverage volume			4.3.1		Pass
Variation of light output			4.3.2		Pass
Minimum and maximum light	intensity		4.3.3		Pass
Light colour			4.3.4		Pass/Red
Light temporal pattern and fre	quency of flashing		4.3.5		Pass/1 Hz
Marking and data			4.3.6		Pass
Synchronization (option with requirements)			4.3.7		Pass
Durability:				None	
Temperature resistance:					
Dry heat (operational)			4.4.1.1		Pass
Dry heat (endurance)			4.4.1.2		Pass
Cold (operational)			4.4.1.3		Pass
Humidity resistance:					
Damp heat, cyclic (operationa)		4.4.2.1		Pass
Damp heat, steady state (endu	irance)	1	4.4.2.2		Pass
Damp heat, cyclic (endurance)			4.4.2.3		Pass
Shock and vibration resistance:					
Shock (operational)			4.4.3.1		Pass
Impact (operational)			4.4.3.2		Pass
Vibration (operational)			4.4.3.3		Pass
Vibration (endurance)			4.4.3.4		Pass
Corrosion resistance:					
SO2 corrosion (endurance)			4.4.4		Pass
Electrical stability:					
EMC, immunity (operational)			4.4.5		Pass

DBI Certification-UK Ltd.

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk \cdot www.dbicertification.co.uk





Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date	
BRE	TE 243617	2010-10-15	
BRE	TE 243617-SW	2010-10-19	
BRE	TE 225766	2006-03-30	
Intertek	103747439LHD-021	2019-09-02	

TECHNICAL BASIS

TECHNICAE DASIS					
File Number			Title		Date
BBQ-230 BOM	666072FULL-0125				2019-05-08
	SY/AV/R/RL BBQ-2	230 AUTRON	ICA		
BBQ-230-IP BOM	666073FULL-0126				2019-05-08
	SY/AV/R/RL/WP B		UTRONICA		2019 05 00
02C077	Critical Componer	nt List			2019-04, Rev. 3.0



DBI Certification-UK Ltd. Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk

