Certificate No.: 8504-UKCA-CPR-UKCSP10233



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

BBQ-130 Addressable indoor base sounder and beacon with isolator

The product fulfils the essential characteristic:

See Annex 1

Applications related to automatic fire alarm systems Intended use:

Placed on the market under the name or trade mark of:

Autronica Fire and Security AS

Bromstadvegen 59 NO-7047 Trondheim

Norway

and produced in the manufacturing plant:

CPA10061

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-3:2001+A1:2002+A2:2006 Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders

Fire detection and fire alarm systems — Part 17: Short circuit isolators EN 54-17:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-12-23 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-12-23.

Merete Poulsen Responsible for evaluation Chris Ellis

Responsible for certification decision



Certificate No.: 8504-UKCA-CPR-UKCSP10233



Annex 1

EXTENT

Type:

BBQ-130 Addressable indoor base sounder and beacon with isolator

Sounder Tones:

Tone	Description	Sounder Pattern Information
a	General Alarm	880Hz, 7*0.5 sec pulse & 1*5.5
b	Evacuate	880 Hz, 1 sec on / 1 sec off, forever
С	Alert	880 Hz ON, forever
d	Bell Test	0.5 sec on every 8 sec
е	Slow Whoop	3.5 sec on / 0.5 sec off, 500-1200 Hz

Note:

The beacon functionality is not included within the scope of this approval.

Performance

Essential characteristics	Clauses in EN 54-3:2001/A	1:2002/A2:2006	Performance
Performance under fire conditions	4.2, 4.3, 5.2,	5.3	Pass
Operational reliability	4.4, 4.5, 4.6,	5.4	Pass
Durability of operational reliability and response delay; temperature resistance	5.5, 5.6, 5.7, 5.	8, 5.9	Pass
Durability of operational reliability; humidity resistance	5.8, 5.9, 5.1	.0	Pass
Durability of operational reliability; corrosion resistance	5.11		Pass
Durability of operational reliability; vibration resistance	5.12 to 5.1	5	Pass
Durability of operational reliability; electrical stability	5.16		Pass
Durability of operational reliability; resistance to ingress	5.17		Pass

^{5.6} and 5.10 applies only to outdoor sounders or outdoor voice sounders. Therefore are these clauses not applicable for this device. 5.16 applies only to sounders or voice sounders with active electronic components

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4 2)	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass

¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices

DBI Certification-UK Ltd.



Version 2022-02-08 Page **2** of **3**

²⁾ There is no provision for connection of ancillary devices and this device does not incorporate a LED indicator. Therefore the clauses 4.2 and 4.3 are not applicable.

Certificate No.: 8504-UKCA-CPR-UKCSP10233



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	TE243617	2010-10-15
BRE	TE 243617-SW	2010-10-19

File Number		Title	Date
	66607051111 0100	Title	
BQ-130 BOM	666078FULL-0133	O ALITRONICA	2019-05-08
	AV BASE SOUNDER BBQ-13	UAUTRONICA	
2C077	Critical Component List		2019-04, Rev. 3.0

DBI Certification-UK Ltd.



Version 2022-02-08 Page **3** of **3**