



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2552</b>	23-Dec-2011	Number 12	Issue date 4-Apr-2024	30-Apr-2025

## Product designation

**Autronica, Type BH-500, smoke detector**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Kidde Australia  
314 Boundary Road, DINGLEY, VIC, AUSTRALIA, 3172

## Registrant

Autronica Fire and Security AS  
Haakon VII's Gate 4, 7483 Trondheim, TRONDHEIM, NORWAY, NO-7483

### Producer

Autronica Fire and Security AS  
Haakon VII's Gate 4, 7483 Trondheim, TRONDHEIM, NORWAY, NO-7483

## Conformance criteria and evaluation

The Autronica, Type BH-500, smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 7240.7-2004, 'Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2552</b>	23-Dec-2011	Number 12	Issue date 4-Apr-2024	30-Apr-2025

Page 2 of 2

## Producer's description

The Autronica, Type BH-500, smoke detector consists of AutoSafe BDH-500 detector head and AutoSafe BWA-100 detector base. It is a plug-in compatible with the Autronica BWA-100 detector base with loop contact. One LED on the sensor pulses as the detector is polled by the associated control and indicating equipment. This LED illuminates red to indicate the alarm status of the device.

This detector has three adjustable sensitivity settings (Clean, Normal and Industry).

The Autronica BH-500 Smoke Detector is 100 mm diameter and 50 mm high.

## Technical specification

The following details are a representative extract of the technical specification for the Autronica, Type BH-500, smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Component	Designation	Sensor + base circuit type
Sensor head	Autronica, Type BHH-500	Analogue Addressable
Base	Autronica, Type BWA-100	
Smoke sensitivity settings	Clean, Normal and Industrial	
Weight:	150g	
Dimensions	100 mm diameter x 50 mm high	
Material:	PC/ABS	
Colour:	White	
Voltage:	16 - 26 Vdc	
Current: Stand by:	< 0.3mA	
Current: External alarm indicator:	6mA	
Degree of protection:	IP44D	
Working temperature:	-20 to +70°C	
Humidity (non-condensing):	Max. 95% RH	
Maintenance:	None	
Service:	Replace if faulty	